

# Listing and Technical Evaluation Report™

Report No: 1501-08



Issue Date: May 14, 2015

Revision Date: May 8, 2024

Subject to Renewal: July 1, 2025

## FastenMaster® FlatLOK® Fasteners

Trade Secret Report Holder:

OMG®, Inc. dba FastenMaster®

Phone: 413-789-0252

Website: [www.fastenmaster.com](http://www.fastenmaster.com)

Email: [mguthrie@omginc.com](mailto:mguthrie@omginc.com)

### CSI Designations:

DIVISION: 06 00 00 - WOOD, PLASTICS AND COMPOSITES


Section: 06 05 23 - Wood, Plastic, and Composite Fastenings

## 1 Innovative Product Evaluated<sup>1</sup>

1.1 FastenMaster FlatLOK Fasteners

## 2 Product Description and Materials

2.1 The innovative product evaluated in this report is shown in **Figure 1**.



**Figure 1.** FastenMaster FlatLOK Fastener

2.2 FlatLOK Fasteners are manufactured using a standard cold-formed process followed by a heat-treating process.

2.3 FlatLOK Fasteners are coated with a proprietary coating that exceeds the protection provided by hot-dipped galvanized coatings conforming to ASTM A153.



- 2.4 FlatLOK Fasteners are approved for use in interior conditions and in chemically treated or untreated lumber where ASTM A153 coatings are approved for use in accordance with IBC Section 2304.10 and IRC Section R317.3.
- 2.4.1 The proprietary coating has been tested and found to exceed the protection provided by code-approved hot-dipped galvanized coatings meeting ASTM A153 (IBC Section 2304.10.6<sup>2</sup> and IRC Section R317.3), allowing for its use in pressure-treated (ACQ) wood.
- 2.4.2 FlatLOK Fasteners are approved for use in fire-retardant treated lumber, provided the conditions set forth by the fire-retardant treated lumber manufacturer are met, including appropriate strength reductions.
- 2.4.3 FlatLOK Fasteners, evaluated in this report are set forth in **Table 1**.

**Table 1. FlatLOK Fasteners Specifications**

Fastener Name	Head (in)			Fastener Length <sup>1</sup> (in)	Shank Diameter <sup>2</sup> (in)	Thread Length <sup>1</sup> (in)	Thread Diameter (in)		Nominal Bending Yield, <sup>3</sup> F <sub>yb</sub> (psi)	Allowable Fastener Strength (lbf)	
	Marking	Diameter	Thickness				Minor	Major		Tensile	Shear
FlatLOK	F2.9FL	0.70	0.095	2 <sup>7</sup> / <sub>8</sub>	0.227	1.75	0.200	0.322	171,600	1,940	1,230
	F3.5FL			3 <sup>1</sup> / <sub>2</sub>							
	F4.0FL			4							
	F4.5FL			4 <sup>1</sup> / <sub>2</sub>							
	F5.0FL			5							
	F6.0FL			6							
	F6.75FL			6 <sup>3</sup> / <sub>4</sub>							

SI: 1 in = 25.4 mm, 1 lb = 4.45 N, 1 psi = 0.00689 MPa

1. Fastener length is measured from the topside of the head to the tip. Thread length includes tapered tip (see **Figure 1**).
2. Shank diameter based on manufactured thickness. Finished dimensions are larger, due to the proprietary coatings added.
3. Bending yield determined at shank diameter.

2.5 As needed, review material properties for design in **Section 6** and to regulatory evaluation in **Section 8**.

### 3 Definitions

- 3.1 New Materials<sup>3</sup> are defined as building materials, equipment, appliances, systems, or methods of construction not provided for by prescriptive and/or legislatively adopted regulations, known as alternative materials.<sup>4</sup> The design strengths and permissible stresses shall be established by tests<sup>5</sup> and/or engineering analysis.<sup>6</sup>
- 3.2 Duly Authenticated Reports<sup>7</sup> and Research Reports<sup>8</sup> are test reports and related engineering evaluations, which are written by an approved agency<sup>9</sup> and/or an approved source.<sup>10</sup>
- 3.2.1 These reports contain intellectual property and/or trade secrets, which are protected by the Defend Trade Secrets Act (DTSA).<sup>11</sup>
- 3.3 An approved agency is “approved” when it is ANAB ISO/IEC 17065 accredited. DrJ Engineering, LLC (DrJ) is listed in the ANAB directory.
- 3.4 An approved source is “approved” when a professional engineer (i.e., Registered Design Professional) is properly licensed to transact engineering commerce. The regulatory authority governing approved sources is the state legislature via its professional engineering regulations.<sup>12</sup>



3.5 Testing and/or inspections conducted for this Duly Authenticated Report were performed by an ISO/IEC 17025 accredited testing laboratory, an ISO/IEC 17020 accredited inspection body, and/or a licensed Registered Design Professional (RDP).

3.5.1 The Center for Building Innovation (CBI) is ANAB<sup>13</sup> ISO/IEC 17025 and ISO/IEC 17020 accredited.

3.6 The regulatory authority shall enforce<sup>14</sup> the specific provisions of each legislatively adopted regulation. If there is a non-conformance, the specific regulatory section and language of the non-conformance shall be provided in writing<sup>15</sup> stating the nonconformance and the path to its cure.

3.7 The regulatory authority shall accept Duly Authenticated Reports from an approved agency and/or an approved source with respect to the quality and manner of use of new materials or assemblies as provided for in regulations regarding the use of alternative materials, designs, or methods of construction.<sup>16</sup>

3.8 ANAB is an International Accreditation Forum (IAF) Multilateral Recognition Arrangement (MLA) signatory where recognition of certificates, validation, and verification statements issued by conformity assessment bodies accredited by all other signatories of the IAF MLA with the appropriate scope, shall be approved.<sup>17</sup> Therefore, all ANAB ISO/IEC 17065 Duly Authenticated Reports are approval equivalent.<sup>18</sup>

3.9 Approval equity is a fundamental commercial and legal principle.<sup>19</sup>

#### **4 Applicable Standards for the Listing; Regulations for the Regulatory Evaluation<sup>20</sup>**

##### **4.1 Standards**

4.1.1 *AISI S904: Test Standard for Determining the Tensile and Shear Strengths of Steel Screws*

4.1.2 *ANSI/AWC NDS: National Design Specification (NDS) for Wood Construction*

4.1.3 *ASTM A153: Standard Specification for Zinc Coating (Hot-Dip) on Iron and Steel Hardware*

4.1.4 *ASTM A510: Standard Specification for General Requirements for Wire Rods and Coarse Round Wire, Carbon Steel, and Alloy Steel*

4.1.5 *ASTM D1761: Standard Test Methods for Mechanical Fasteners in Wood*

4.1.6 *ASTM F1575: Standard Test Method for Determining Bending Yield Moment of Nails, Spikes, and Dowel-Type Threaded Fasteners*

##### **4.2 Regulations**

4.2.1 *IBC – 15, 18, 21: International Building Code®*

4.2.2 *IRC – 15, 18, 21: International Residential Code®*

#### **5 Listed<sup>21</sup>**

5.1 Equipment, materials, products or services included in a List published by a nationally recognized testing laboratory (i.e., CBI), approved agency (i.e., CBI and DrJ), and/or approved source (i.e., DrJ) or other organization concerned with product evaluation (i.e., DrJ) that maintains periodic inspection (i.e., CBI) of production of listed equipment or materials, and whose listing states either that the equipment or material meets nationally recognized standards or has been tested and found suitable for use in a specified manner.

## 6 Tabulated Properties Generated from Nationally Recognized Standards

### 6.1 General

6.1.1 FlatLOK Fasteners are used to attach wood structural framing members in conventional light-frame construction and to provide resistance to lateral and withdrawal loads applied parallel and/or perpendicular to the structural framing member.

6.1.1.1 Wood structural framing members may be solid sawn lumber or Structural Composite Lumber (SCL) conforming to all pertinent provisions of ASTM D5456.

6.1.1.1.1 Where connection property values for SCL is listed, SCL shall have a published equivalent specific gravity meeting the minimum specified value in the respective table. Refer to the SCL manufacturer for the details.

6.1.1.2 See **Section 9** for installation requirements.

6.1.2 FlatLOK Fasteners are installed without lead holes.


### 6.1.3 Design:

6.1.3.1 Design of FlatLOK Fasteners is governed by the applicable code and the provisions for dowel-type fasteners in NDS.

6.1.3.2 Unless otherwise noted, adjustment of the design stresses for duration of load shall be in accordance with the applicable code.

### 6.2 FlatLOK Fasteners Reference Lateral Design Values – Face Gain Applications

6.2.1 The reference lateral design values for shear load perpendicular and parallel to grain for FlatLOK Fasteners as depicted in **Figure 2**, are specified in **Table 2**, **Table 3**, **Table 4**, **Table 5** and **Table 6**.



**Figure 2.** Loading Diagram for Shear Perpendicular to Grain



**Table 2. FlatLOK Fasteners Reference Lateral Design Values – Dimensional Lumber with Head Side Loading<sup>1,2</sup>**

FlatLOK Fastener	Fastener Length (in)	Side Member Thickness (in)	Min. Penetration into Main Member (in)	Lateral Design Values (lbf) by Species (Specific Gravity) & Load Orientation					
				SPF (0.42)		DF-L (0.50)		SP (0.55)	
				Z Perp	Z Para	Z Perp	Z Para	Z Perp	Z Para
FL278	2 <sup>7</sup> / <sub>8</sub>	1 <sup>1</sup> / <sub>2</sub>	1 <sup>3</sup> / <sub>8</sub>	200	150	240	235	270	270
FL312	3 <sup>1</sup> / <sub>2</sub>	1 <sup>1</sup> / <sub>2</sub>	2	200	150	240	235	270	270
FL004	4	1 <sup>1</sup> / <sub>2</sub>	2 <sup>1</sup> / <sub>2</sub>	200	150	240	235	270	270
FL412	4 <sup>1</sup> / <sub>2</sub>	1 <sup>1</sup> / <sub>2</sub>	3	320	245	480	350	550	440
FL005	5	1 <sup>1</sup> / <sub>2</sub>	3	320	245	480	350	550	440
FL006	6	1 <sup>1</sup> / <sub>2</sub>	3	320	245	480	350	550	440
FL634	6 <sup>3</sup> / <sub>4</sub>	1 <sup>1</sup> / <sub>2</sub>	3	320	245	480	350	550	440

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Reference lateral design values apply to two-member single shear connections where both members are of the same specific gravity and the fastener is oriented perpendicular to grain. Where the members are of different specific gravities, use the lower of the two.
- Values shall be adjusted by all applicable adjustment factors per NDS.

**Table 3. FlatLOK Fasteners Reference Lateral Design Values – Dimensional Lumber with Point Side Loading<sup>1,2</sup>**

FlatLOK Fastener	Fastener Length (in)	Side Member Thickness (in)	Min. Penetration into Main Member (in)	Lateral Design Values (lbf) by Species (Specific Gravity) & Load Orientation					
				SPF (0.42)		DF-L (0.50)		SP (0.55)	
				Z Perp	Z Para	Z Perp	Z Para	Z Perp	Z Para
FL412	4 <sup>1</sup> / <sub>2</sub>	3	1 <sup>1</sup> / <sub>2</sub>	200	–	260	–	290	–
FL006	6	4 <sup>1</sup> / <sub>2</sub>	1 <sup>1</sup> / <sub>2</sub>	200	–	260	–	290	–

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Reference lateral design values apply to two-member single shear connections where both members are of the same specific gravity and the fastener is oriented perpendicular to grain. Where the members are of different specific gravities, use the lower of the two.
- Values shall be adjusted by all applicable adjustment factors per NDS.



**Table 4. FlatLOK Fasteners Reference Lateral Design Values – SCL in Face Grain Applications with Head Side Loading<sup>1,2</sup>**

FlatLOK Fastener	Fastener Length (in)	Side Member Thickness (in)	Min. Penetration into Main Member (in)	Lateral Design Values (lbf) by Species (Specific Gravity) & Load Orientation			
				LVL (0.50)		LSL (0.50)	
				Z Perp	Z Para	Z Perp	Z Para
FL278	2 <sup>7</sup> / <sub>8</sub>	1 <sup>1</sup> / <sub>4</sub>	1 <sup>1</sup> / <sub>4</sub>	375	235	435	235
FL312	3 <sup>1</sup> / <sub>2</sub>	1 <sup>3</sup> / <sub>4</sub>	1 <sup>3</sup> / <sub>4</sub>	375	235	435	235
FL005	5	1 <sup>3</sup> / <sub>4</sub>	3 <sup>1</sup> / <sub>4</sub>	560	350	480	350
FL634	6 <sup>3</sup> / <sub>4</sub>	1 <sup>3</sup> / <sub>4</sub>	5	560	350	480	350
FL634	6 <sup>3</sup> / <sub>4</sub>	3 <sup>1</sup> / <sub>2</sub>	3 <sup>1</sup> / <sub>4</sub>	560	350	480	350

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Reference lateral design values apply to two-member single shear connections where both members are of the same specific gravity and the fastener is oriented perpendicular to grain. Where the members are of different specific gravities, use the lower of the two.
- Values shall be adjusted by all applicable adjustment factors per NDS.

**Table 5. FlatLOK Fasteners Reference Lateral Design Values – SCL with Point Side Loading<sup>1,2</sup>**

FlatLOK Fastener	Fastener Length (in)	Side Member Thickness (in)	Min. Penetration into Main Member (in)	Lateral Design Values (lbf) by Species (Specific Gravity) & Load Orientation			
				LVL (0.50)		LSL (0.50)	
				Z Perp	Z Para	Z Perp	Z Para
FL312	3 <sup>1</sup> / <sub>2</sub>	1 <sup>3</sup> / <sub>4</sub>	1 <sup>3</sup> / <sub>4</sub>	330	235	260	235
FL005	5	3 <sup>1</sup> / <sub>2</sub>	1 <sup>1</sup> / <sub>2</sub>	330	235	260	235
FL634	6 <sup>3</sup> / <sub>4</sub>	5	1 <sup>3</sup> / <sub>4</sub>	330	235	260	235
FL634	6 <sup>3</sup> / <sub>4</sub>	3 <sup>1</sup> / <sub>4</sub>	3 <sup>1</sup> / <sub>2</sub>	330	235	260	235

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Reference lateral design values apply to two-member single shear connections where both members are of the same specific gravity and the fastener is oriented perpendicular to grain. Where the members are of different specific gravities, use the lower of the two.
- Values shall be adjusted by all applicable adjustment factors per NDS.



6.3 FlatLOK Fasteners Reference Lateral Design Values – Edge Grain Applications

**Table 6.** FlatLOK Fasteners Reference Lateral Design Values – Dimensional Lumber & SCL in Edge Grain Applications<sup>1,2</sup>

FlatLOK Fastener	Fastener Length (in)	Side Member Thickness (in)	Min. Penetration into Main Member (in)	Lateral Design Values (lbf) by Species (Specific Gravity) Parallel to Grain Loading			
				SPF (0.42)	DF-L (0.50)	SP (0.55)	LSL <sup>3</sup> (0.50)
FL006	6	3 1/2	2 1/2	235	300	285	225

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Reference lateral design values apply to two-member single shear connections where both members are of the same specific gravity and the fastener is oriented perpendicular to grain. Where the members are of different specific gravities, use the lower of the two.
- Values shall be adjusted by all applicable adjustment factors per NDS.
- Minimum thickness 1 1/4".

6.4 FlatLOK Fasteners Reference Withdrawal Design Values

- 6.4.1 The design provisions for withdrawal noted in NDS Table 12.2B apply to FlatLOK Fasteners unless otherwise noted in this report.
- 6.4.2 Reference withdrawal design values for FlatLOK Fasteners in select lumber species and SCL products are specified in **Table 7**, **Table 8** and **Table 9**.

**Table 7.** FlatLOK Fasteners Reference Withdrawal Design Values – Face Grain Applications<sup>1,2</sup>

Thread Penetration into Main Member (in)	Reference Withdrawal Design Values (lbf) by Species (Specific Gravity)				
	SPF (0.42)	DF-L (0.50)	SP (0.55)	LVL (0.50)	LSL (0.50)
1	90	145	140	140	140
1 1/4	125	190	210	210	220
1 1/2	160	240	280	275	295
1 3/4	195	285	355	345	375
2	230	335	425	410	450

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Values shall be adjusted by all applicable adjustment factors per NDS Section 11.3 for wood screws.
- Fastener penetration is the threaded length embedded in the main member, including the tip.



**Table 8. FlatLOK Fasteners Reference Withdrawal Design Values – Edge Grain Applications<sup>1,2</sup>**

Thread Penetration into Main Member (in)	Reference Withdrawal Design Values (lbf) by Species (Specific Gravity)				
	SPF (0.42)	DF-L (0.50)	SP (0.55)	LVL (0.50)	LSL (0.50)
1	100	160	125	125	125
1¼	145	215	190	185	195
1½	190	275	260	240	265
1¾	235	330	325	300	335
2	280	390	390	360	405

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Values shall be adjusted by all applicable adjustment factors per NDS Section 11.3 for wood screws.
- Fastener penetration is the threaded length embedded in the main member, including the tip.

**Table 9. FlatLOK Fasteners Reference Withdrawal Design Values – End Grain Applications<sup>1,2</sup>**

Thread Penetration into Main Member (in)	Reference Withdrawal Design Values (lbf) by Species (Specific Gravity)				
	SPF (0.42)	DF-L (0.50)	SP (0.55)	LVL (0.50)	LSL (0.50)
2	175	295	285	–	–

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Values shall be adjusted by all applicable adjustment factors per NDS Section 11.3 for wood screws.
- Fastener penetration is the threaded length embedded in the main member, including the tip.

**6.5 FlatLOK Fasteners Reference Head Pull-Through Design Values**

6.5.1 The reference design values for head pull-through for FlatLOK Fasteners are specified in **Table 10**.

**Table 10. FlatLOK Fasteners Reference Head Pull-Through Design Values<sup>1</sup>**


Min. Side Member Thickness (in)	Head Pull-Through Design Values (lbf) by Species (Specific Gravity)					
	SPF (0.42)	DF-L (0.50)	SP (0.55)	LVL (0.50)	LSL (0.50)	7/16" OSB
1.5	395	530	595	650	750	100

SI: 1 in = 25.4 mm, 1 lb = 4.45 N

- Values shall be adjusted by all applicable adjustment factors per NDS Section 11.3 for wood screws.

6.5.2 Edge and End Distance:

6.5.2.1 Fastener edge and end distances shall be as specified in **Figure 3** and **Table 11**.



**Figure 3.** FlatLOK Fasteners Edge and End Distance Requirements

**Table 11.** FlatLOK Fasteners Edge and End Distance Requirements

Letter	Installed Condition	Minimum Distance or Spacing (in) <sup>1</sup>		
		Face	Edge	End
A	Min. End Distance	6	6	1 <sup>3</sup> / <sub>4</sub>
B	Min. Edge Distance	1 <sup>3</sup> / <sub>4</sub>	<sup>3</sup> / <sub>4</sub>	<sup>3</sup> / <sub>4</sub>
C	Min. Spacing Between Fasteners in a Row	3 <sup>1</sup> / <sub>2</sub>	3 <sup>1</sup> / <sub>2</sub>	3 <sup>1</sup> / <sub>2</sub>
D	Min. Spacing Between Non-Staggered Rows	3 <sup>1</sup> / <sub>2</sub>	N/A	N/A
E	Min. Spacing Between Staggered Rows	<sup>5</sup> / <sub>8</sub>	N/A	N/A
F	Min. Stagger Between Fasteners in Adjacent Rows	<sup>5</sup> / <sub>8</sub>	N/A	N/A

St: 1 in = 25.4 mm

1. Edge distances, end distances and spacing of fasteners shall be sufficient to prevent splitting of the wood or as shown in this table, whichever is more restrictive.

6.6 Where the application falls outside of the performance evaluation, conditions of use and/or installation requirements set forth herein, alternative techniques shall be permitted in accordance with accepted engineering practice and experience. This includes but is not limited to the following areas of engineering: mechanics or materials, structural, building science, and fire science.



## 7 Certified Performance<sup>22</sup>

- 7.1 All construction methods shall conform to accepted engineering practices to ensure durable, livable, and safe construction and shall demonstrate acceptable workmanship reflecting journeyman quality of work of the various trades.<sup>23</sup>
- 7.2 The strength and rigidity of the component parts and/or the integrated structure shall be determined by engineering analysis or by suitable load tests to simulate the actual loads and conditions of application that occur.<sup>24</sup>

## 8 Regulatory Evaluation and Accepted Engineering Practice

- 8.1 FastenMaster FlatLOK Fasteners comply with the following legislatively adopted regulations and/or accepted engineering practice for the following reasons:
  - 8.1.1 FlatLOK Fasteners were tested and evaluated to determine their structural resistance properties which are used to develop reference design values for Allowable Stress Design (ASD).
  - 8.1.2 The following properties were evaluated:
    - 8.1.2.1 Withdrawal strength in accordance with ASTM D1761
    - 8.1.2.2 Head pull-through in accordance with ASTM D1761
    - 8.1.2.3 Lateral resistance for use as an alternative to metal straps, ties or fasteners in shear (lateral) loaded applications either parallel or perpendicular to wood grain in accordance with ASTM D1761
  - 8.1.3 Use of FlatLOK Fasteners in wet service conditions is outside the scope of this report.
- 8.2 Any building code, regulation, and/or accepted engineering evaluations (i.e., research reports, Duly Authenticated Reports, etc.) that are conducted for this Listing were performed by DrJ Engineering, LLC (DrJ), an ISO/IEC 17065 accredited certification body and a professional engineering company operated by RDP/approved sources. DrJ is qualified<sup>25</sup> to practice product and regulatory compliance services within its scope of accreditation and engineering expertise, respectively.
- 8.3 Engineering evaluations are conducted with DrJ's ANAB accredited ICS code scope of expertise, which are also its areas of professional engineering competence.
- 8.4 Any regulation specific issues not addressed in this section are outside the scope of this report.

## 9 Installation

- 9.1 Installation shall comply with the approved construction documents, the manufacturer installation instructions, this report and the applicable building code.
- 9.2 In the event of a conflict between the manufacturer installation instructions and this report, the more restrictive shall govern.
- 9.3 FlatLOK Fasteners shall be installed in accordance with the applicable code, the approved construction documents, this report, the manufacturer installation instructions, NDS and standard framing practice as applied to wood fasteners.
- 9.4 Use a 1/2" low RPM/high torque drill to drive the fastener head flush with the surface of the framing member using the driver bit included with the fasteners.
- 9.5 Screws shall not be overdriven.



## 10 Substantiating Data

- 10.1 Testing has been performed under the supervision of a professional engineer and/or under the requirements of ISO/IEC 17025 as follows:
  - 10.1.1 Withdrawal, head pull-through and lateral resistance testing in accordance with ASTM D1761
  - 10.1.2 Tensile and shear strength data from approved sources tested in accordance with AISI S904
  - 10.1.3 Bending yield strength data from approved sources tested in accordance with ASTM F1575
- 10.2 Information contained herein may include the result of testing and/or data analysis by sources that are approved agencies, approved sources, and/or RDPs. Accuracy of external test data and resulting analysis is relied upon.
- 10.3 Where pertinent, testing and/or engineering analysis are based upon provisions that have been codified into law through state or local adoption of regulations and standards. The developers of these regulations and standards are responsible for the reliability of published content. DrJ's engineering practice may use a regulation-adopted provision as the control. A regulation-endorsed control versus a simulation of the conditions of application to occur establishes a new material as being equivalent to the regulatory provision in terms of quality, strength, effectiveness, fire resistance, durability, and safety.
- 10.4 The accuracy of the provisions provided herein may be reliant upon the published properties of raw materials, which are defined by the grade mark, grade stamp, mill certificate, or Duly Authenticated Reports from approved agencies and/or approved sources provided by the supplier. These are presumed to be minimum properties and relied upon to be accurate. The reliability of DrJ's engineering practice, as contained in this Duly Authenticated Report, may be dependent upon published design properties by others.
- 10.5 Testing and engineering analysis: The strength, rigidity, and/or general performance of component parts and/or the integrated structure are determined by suitable tests that simulate the actual conditions of application that occur and/or by accepted engineering practice and experience.<sup>26</sup>
- 10.6 Where additional condition of use and/or regulatory compliance information is required, please search for FlatLOK Fasteners on the DrJ Certification website.

## 11 Findings

- 11.1 As outlined in **Section 6**, FlatLOK Fasteners have performance characteristics that were tested and/or meet applicable regulations and are suitable for use pursuant to their specified purpose.
- 11.2 When used and installed in accordance with this Duly Authenticated Report and the manufacturer installation instructions, FlatLOK Fasteners shall be approved for the following applications:
  - 11.2.1 As an alternative to those fasteners prescribed by the applicable code for wood-to-wood connections.
- 11.3 Unless exempt by state statute, when FlatLOK Fasteners are to be used as a structural and/or building envelope component in the design of a specific building, the design shall be performed by an RDP.
- 11.4 Any application specific issues not addressed herein can be engineered by an RDP. Assistance with engineering is available from FastenMaster.
- 11.5 IBC Section 104.11 (IRC Section R104.11 and IFC Section 104.10<sup>27</sup> are similar) in pertinent part states:

**104.11 Alternative materials, design and methods of construction and equipment.** The provisions of this code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by this code. Where the alternative material, design or method of construction is not approved, the building official shall respond in writing, stating the reasons the alternative was not approved.



- 11.6 **Approved:**<sup>28</sup> Building regulations require that the building official shall accept Duly Authenticated Reports.<sup>29</sup>
- 11.6.1 An approved agency is “approved” when it is ANAB ISO/IEC 17065 accredited.
- 11.6.2 An approved source is “approved” when an RDP is properly licensed to transact engineering commerce.
- 11.6.3 Federal law, Title 18 US Code Section 242, requires that where the alternative product, material, service, design, assembly, and/or method of construction is not approved, the building official shall respond in writing, stating the reasons why the alternative was not approved. Denial without written reason deprives a protected right to free and fair competition in the marketplace.
- 11.7 DrJ is a licensed engineering company, employs licensed RDPs and is an ANAB-Accredited Product Certification Body – Accreditation #1131.
- 11.8 Through the IAF Multilateral Agreements (MLA), this Duly Authenticated Report can be used to obtain product approval in any jurisdiction or country because all ANAB ISO/IEC 17065 Duly Authenticated Reports are equivalent.<sup>30</sup>

## 12 Conditions of Use

- 12.1 Material properties shall not fall outside the boundaries defined in **Section 6**.
- 12.2 As defined in **Section 6**, where material and/or engineering mechanics properties are created for load resisting design purposes, the resistance to the applied load shall not exceed the ability of the defined properties to resist those loads using the principles of accepted engineering practice.
- 12.3 Use of FlatLOK Fasteners in locations exposed to saltwater or saltwater spray is outside the scope of this report.
- 12.4 For conditions not covered in this report, connections shall be designed in accordance with generally accepted engineering practice.
- 12.5 When required by adopted legislation and enforced by the building official, also known as the authority having jurisdiction (AHJ) in which the project is to be constructed:
- 12.5.1 Any calculations incorporated into the construction documents shall conform to accepted engineering practice and, when prepared by an approved source, shall be approved when signed and sealed.
- 12.5.2 This report and the installation instructions shall be submitted at the time of permit application.
- 12.5.3 This innovative product has an internal quality control program and a third-party quality assurance program.
- 12.5.4 At a minimum, this innovative product shall be installed per **Section 9** of this report.
- 12.5.5 The review of this report by the AHJ shall comply with IBC Section 104 and IBC Section 105.4.
- 12.5.6 This innovative product has an internal quality control program and a third party quality assurance program in accordance with IBC Section 104.4, IBC Section 110.4, IBC Section 1703, IRC Section R104.4, and IRC Section R109.2.
- 12.5.7 The application of this innovative product in the context of this report is dependent upon the accuracy of the construction documents, implementation of installation instructions, inspection as required by IBC Section 110.3, IRC Section R109.2, and any other regulatory requirements that may apply.
- 12.6 The approval of this report by the AHJ shall comply with IBC Section 1707.1, where legislation states in part, “*the building official shall accept duly authenticated reports from approved agencies in respect to the quality and manner of use of new material or assemblies as provided for in Section 104.11,*” all of IBC Section 104, and IBC Section 105.4.
- 12.7 Design loads shall be determined in accordance with the regulations adopted by the jurisdiction in which the project is to be constructed and/or by the building designer (i.e., owner or RDP).
- 12.8 The actual design, suitability, and use of this report for any particular building, is the responsibility of the owner or the authorized agent of the owner.



### 13 Identification

- 13.1 The innovative product listed in **Section 1.1** is identified by a label on the board or packaging material bearing the manufacturer name, product name, this report number, and other information to confirm code compliance.
- 13.2 Additional technical information can be found at [www.fastenmaster.com](http://www.fastenmaster.com).

### 14 Review Schedule

- 14.1 This report is subject to periodic review and revision. For the latest version, visit [drjcertification.org](http://drjcertification.org).
- 14.2 For information on the status of this report, please contact [DrJ Certification](#).

### 15 Approved for Use Pursuant to U.S. and International Legislation Defined in Appendix A

- 15.1 FastenMaster FlatLOK Fasteners are included in this report published by an approved agency that is concerned with evaluation of products or services, maintains periodic inspection of the production of listed materials or periodic evaluation of services. This report states either that the material, product, or service meets recognized standards or has been tested and found suitable for a specified purpose. This report meets the legislative intent and definition of being acceptable to the AHJ.



## Appendix A

### 1 Legislation that Authorizes AHJ Approval

- 1.1 **Fair Competition:** State legislatures have adopted Federal regulations for the examination and approval of building code referenced and alternative products, materials, designs, services, assemblies and/or methods of construction that:
  - 1.1.1 Advance innovation
  - 1.1.2 Promote competition so all businesses have the opportunity to compete on price and quality in an open market on a level playing field unhampered by anticompetitive constraints
  - 1.1.3 Benefit consumers through lower prices, better quality, and greater choice
- 1.2 **Adopted Legislation:** The following local, state, and federal regulations affirmatively authorize this innovative product to be approved by AHJs, delegates of building departments, and/or delegates of an agency of the federal government:
  - 1.2.1 Interstate commerce is governed by the Federal Department of Justice to encourage the use of innovative products, materials, designs, services, assemblies, and/or methods of construction. The goal is to “*protect economic freedom and opportunity by promoting free and fair competition in the marketplace.*”
  - 1.2.2 Title 18 US Code Section 242 affirms and regulates the right of individuals and businesses to freely and fairly have new products, materials, designs, services, assemblies, and/or methods of construction approved for use in commerce. Disapproval of alternatives shall be based upon non-conformance with respect to specific provisions of adopted legislation and shall be provided in writing stating the reasons why the alternative was not approved, with reference to the specific legislation violated.
  - 1.2.3 The federal government and each state have a public records act. In addition, each state also has legislation that mimics the federal Defend Trade Secrets Act 2016 (DTSA),<sup>31</sup> where providing test reports, engineering analysis and/or other related IP/TS is subject to prison of not more than ten years<sup>32</sup> and/or a \$5,000,000 fine or 3 times the value of<sup>33</sup> the Intellectual Property (IP) and Trade Secrets (TS).
    - 1.2.3.1 Compliance with public records and trade secret legislation requires approval through the use of Listings, certified reports, Technical Evaluation Reports, Duly Authenticated Reports, and/or research reports prepared by approved agencies and/or approved sources.
  - 1.2.4 For new materials<sup>34</sup> that are not specifically provided for in any regulation, the design strengths and permissible stresses shall be established by tests, where suitable load tests simulate the actual loads and conditions of application that occur.
  - 1.2.5 The design strengths and permissible stresses of any structural material shall conform to the specifications and methods of design using accepted engineering practice.<sup>35</sup>
  - 1.2.6 The commerce of approved sources (i.e., registered PEs) is regulated by professional engineering legislation. Professional engineering commerce shall always be approved by AHJs, except where there is evidence provided in writing, that specific legislation have been violated by an individual registered PE.
  - 1.2.7 The AHJ shall accept Duly Authenticated Reports from approved agencies in respect to the quality and manner of use of new materials or assemblies as provided for in IBC Section 104.11.<sup>36</sup>



- 1.3 **Approved<sup>37</sup> by Los Angeles:** The Los Angeles Municipal Code (LAMC) states in pertinent part that the provisions of LAMC are not intended to prevent the use of any material, device, or method of construction not specifically prescribed by LAMC. The Department shall use Part III, Recognized Standards in addition to Part II, Uniform Building Code Standards of Division 35, Article 1, Chapter IX of the LAMC in evaluation of products for approval where such standard exists for the product or the material and may use other approved standards that apply. Whenever tests or certificates of any material or fabricated assembly are required by Chapter IX of the LAMC, such tests or certification shall be made by a testing agency approved by the Superintendent of Building to conduct such tests or provide such certifications. The testing agency shall publish the scope and limitation(s) of the listed material or fabricated assembly.<sup>38</sup> The Superintendent of Building Approved Testing Agency Roster is provided by the Los Angeles Department of Building and Safety (LADBS). The Center for Building Innovation (CBI) Certificate of Approval License is TA24945. Tests and certifications found in a DrJ Listing are LAMC approved. In addition, the Superintendent of Building shall accept Duly Authenticated Reports from approved agencies in respect to the quality and manner of use of new materials or assemblies as provided for in the California Building Code (CBC) Section 1707.1.<sup>39</sup>
- 1.4 **Approved by Chicago:** The Municipal Code of Chicago (MCC) states in pertinent part that an Approved Agency is a Nationally Recognized Testing Laboratory (NRTL) acting within its recognized scope and/or a certification body accredited by the American National Standards Institute (ANSI) acting within its accredited scope. Construction materials and test procedures shall conform to the applicable standards listed in the MCC. Sufficient technical data shall be submitted to the building official to substantiate the proposed use of any product, material, service, design, assembly, and/or method of construction not specifically provided for in the MCC. This technical data shall consist of research reports from approved sources (i.e., MCC defined Approved Agencies).
- 1.5 **Approved by New York City:** The 2022 NYC Building Code (NYCBC) states in part that an approved agency shall be deemed<sup>40</sup> an approved testing agency via ISO/IEC 17025 accreditation, an approved inspection agency via ISO/IEC 17020 accreditation, and an approved product evaluation agency via ISO/IEC 17065 accreditation. Accrediting agencies, other than federal agencies, must be members of an internationally recognized cooperation of laboratory and inspection accreditation bodies subject to a mutual recognition agreement<sup>41</sup> (i.e., ANAB, International Accreditation Forum [IAF], etc.).
- 1.6 **Approved by Florida:** Statewide approval of products, methods, or systems of construction shall be approved, without further evaluation by:
- 1.6.1 A certification mark or listing of an approved certification agency,
  - 1.6.2 A test report from an approved testing laboratory,
  - 1.6.3 A product evaluation report based upon testing or comparative or rational analysis, or a combination thereof, from an approved product evaluation entity, or
  - 1.6.4 A product evaluation report based upon testing, comparative or rational analysis, or a combination thereof, developed, signed and sealed by a professional engineer or architect, licensed in Florida.
  - 1.6.5 For local product approval, products or systems of construction shall demonstrate compliance with the structural wind load requirements of the Florida Building Code (FBC) through one of the following methods:
    - 1.6.5.1 A certification mark, listing or label from a commission-approved certification agency indicating that the product complies with the code,
    - 1.6.5.2 A test report from a commission-approved testing laboratory indicating that the product tested complies with the code,
    - 1.6.5.3 A product-evaluation report based upon testing, comparative or rational analysis, or a combination thereof, from a commission-approved product evaluation entity which indicates that the product evaluated complies with the code,



- 1.6.5.4 A product-evaluation report or certification based upon testing or comparative or rational analysis, or a combination thereof, developed and signed and sealed by a Florida professional engineer or Florida registered architect, which indicates that the product complies with the code, or
- 1.6.5.5 A statewide product approval issued by the Florida Building Commission.
- 1.6.6 The [Florida Department of Business and Professional Regulation \(DBPR\)](#) website provides a listing of companies certified as a [Product Evaluation Agency](#) (i.e., EVLMiami 13692), a [Product Certification Agency](#) (i.e., CER10642), and as a [Florida Registered Engineer](#) (i.e., ANE13741).
- 1.7 **Approved by Miami-Dade County (i.e., Notice of Acceptance [NOA]):** A Florida statewide approval is an NOA. An NOA is a Florida local product approval. By Florida law, Miami-Dade County shall accept the statewide and local Florida Product Approval as provided for in Florida legislation [553.842](#) and [553.8425](#).
- 1.8 **Approved by New Jersey:** Pursuant to the 2018 Building Code of New Jersey in [IBC Section 1707.1 General](#),<sup>42</sup> it states: “*In the absence of approved rules or other approved standards, the building official shall accept duly authenticated reports from [approved agencies](#) in respect to the quality and manner of use of new materials or assemblies as provided for in the administrative provisions of the Uniform Construction Code (N.J.A.C. 5:23)*”.<sup>43</sup> Furthermore N.J.A.C 5:23-3.7 states: “*Municipal approvals of alternative materials, equipment, or methods of construction.*”
  - 1.8.1 **Approvals:** Alternative materials, equipment, or methods of construction shall be approved by the appropriate subcode official provided the proposed design is satisfactory and that the materials, equipment, or methods of construction are suitable for the intended use and are at least the equivalent in quality, strength, effectiveness, fire resistance, durability, and safety of those conforming with the requirements of the regulations.
    - 1.8.1.1 A field evaluation label and report or letter issued by a nationally recognized testing laboratory verifying that the specific material, equipment, or method of construction meets the identified standards or has been tested and found to be suitable for the intended use, shall be accepted by the appropriate subcode official as meeting the requirements of the above.
    - 1.8.1.2 Reports of engineering findings issued by nationally recognized evaluation service programs such as but not limited to, the Building Officials and Code Administrators (BOCA), the International Conference of Building Officials (ICBO), the Southern Building Code Congress International (SBCCI), the International Code Council (ICC), and the National Evaluation Service, Inc., shall be accepted by the appropriate subcode official as meeting the requirements of the above.
  - 1.8.2 The [New Jersey Department of Community Affairs](#) has confirmed that technical evaluation reports, from any accredited entity listed by [ANAB](#), meets the requirements of item the previous paragraph, given that the listed entities are no longer in existence and/or do not provide “*reports of engineering findings.*”
- 1.9 **Approved by the Code of Federal Regulations Manufactured Home Construction and Safety Standards:** Pursuant to Title 24, Subtitle B, Chapter XX, [Part 3282.14](#)<sup>44</sup> and [Part 3280](#),<sup>45</sup> the Department encourages innovation and the use of new technology in manufactured homes. The design and construction of a manufactured home shall conform to the provisions of Part 3282 and Part 3280 where key approval provisions in mandatory language follow:
  - 1.9.1 “*All construction methods shall be in conformance with accepted engineering practices.*”
  - 1.9.2 “*The strength and rigidity of the component parts and/or the integrated structure shall be determined by engineering analysis or by suitable load tests to simulate the actual loads and conditions of application that occur.*”
  - 1.9.3 “*The design stresses of all materials shall conform to accepted engineering practice.*”



- 1.10 **Approval by US, Local and State Jurisdictions in General:** In all other local and state jurisdictions, the adopted building code legislation states in pertinent part that:
- 1.10.1 For new materials that are not specifically provided for in this code, the design strengths and permissible stresses shall be established by tests.<sup>46</sup>
  - 1.10.2 For innovative alternatives and/or methods of construction, the building official shall accept Duly Authenticated Reports from approved agencies with respect to the quality and manner of use of new materials or assemblies.<sup>47</sup>
    - 1.10.2.1 An approved agency is “approved” when it is ANAB ISO/IEC 17065 accredited. DrJ Engineering, LLC (DrJ) is in the ANAB directory.
    - 1.10.2.2 An approved source is “approved” when an RDP is properly licensed to transact engineering commerce. The regulatory authority governing approved sources is the state legislature via its professional engineering regulations.<sup>48</sup>
  - 1.10.3 The design strengths and permissible stresses of any structural material...shall conform to the specifications and methods of design of accepted engineering practice performed by an approved source.<sup>49</sup>
- 1.11 **Approval by International Jurisdictions:** The USMCA and GATT agreements provide for approval of innovative materials, designs, services, and/or methods of construction through the Agreement on Technical Barriers to Trade and the IAF Multilateral Recognition Arrangement (MLA), where these agreements:
- 1.11.1 State that conformity assessment procedures (i.e., ISO/IEC 17020, 17025, 17065, etc.) are prepared, adopted, and applied so as to grant access for suppliers of like products originating in the territories of other Members under conditions no less favourable than those accorded to suppliers of like products of national origin or originating in any other country, in a comparable situation.
  - 1.11.2 **Approved:** The purpose of the MLA is to ensure mutual recognition of accredited certification and validation/verification statements between signatories to the MLA and subsequently, acceptance of accredited certification and validation/verification statements in many markets based on one accreditation for the timely approval of innovative materials, designs, services, and/or methods of construction.
  - 1.11.3 ANAB is an IAF-MLA signatory where recognition of certificates, validation, and verification statements issued by conformity assessment bodies accredited by all other signatories of the IAF MLA, with the appropriate scope, shall be approved.<sup>50</sup>
  - 1.11.4 Therefore, all ANAB ISO/IEC 17065 Duly Authenticated Reports are approval equivalent.<sup>51</sup>
- 1.12 Approval equity is a fundamental commercial and legal principle.<sup>52</sup>



# Notes

- 1 For more information, visit [drjcertification.org](http://drjcertification.org) or call us at 608-310-6748.
- 2 [2018 IBC Section 2304.10.5](#)
- 3 <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1702>
- 4 Alternative Materials, Design and Methods of Construction and Equipment: The provisions of any regulation code are not intended to prevent the installation of any material or to prohibit any design or method of construction not specifically prescribed by a regulation. Please review <https://www.justice.gov/atr/mission> and <https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#104.11>
- 5 <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1706>:-:text=the%20design%20strengths%20and%20permissible%20stresses%20shall%20be%20established%20by%20tests%20as
- 6 The design strengths and permissible stresses of any structural material shall conform to the specifications and methods of design of accepted engineering practice. <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1706>:-:text=shall%20conform%20to%20the%20specifications%20and%20methods%20of%20design%20of%20accepted%20engineering%20practice
- 7 <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1707>:-:text=the%20building%20official%20shall%20accept%20duly%20authenticated%20reports%20from%20approved%20agencies
- 8 <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1703.4.2>
- 9 [https://up.codes/viewer/wyoming/ibc-2021/chapter/2/definitions#approved\\_agency](https://up.codes/viewer/wyoming/ibc-2021/chapter/2/definitions#approved_agency)
- 10 [https://up.codes/viewer/wyoming/ibc-2021/chapter/2/definitions#approved\\_source](https://up.codes/viewer/wyoming/ibc-2021/chapter/2/definitions#approved_source)
- 11 <https://www.law.cornell.edu/uscode/text/18/1832> (b) Any organization that commits any offense described in subsection (a) shall be fined not more than the greater of \$5,000,000 or 3 times the value of the stolen trade secret to the organization, including expenses for research and design and other costs of reproducing the trade secret that the organization has thereby avoided. The federal government and each state have a public records act. To follow DTSA and comply state public records and trade secret legislation requires approval through ANAB ISO/IEC 17065 accredited certification bodies or approved sources. For more information, please review this website: [Intellectual Property and Trade Secrets](#).
- 12 <https://www.nspe.org/resources/issues-and-advocacy/professional-policies-and-position-statements/regulation-professional> AND <https://apassociation.org/list-of-engineering-boards-in-each-state-archive/>
- 13 <https://www.cbiteest.com/accreditation/>
- 14 <https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#104.11>:-:text=to%20enforce%20the%20provisions%20of%20this%20code
- 15 <https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#104.11>:-:text=Where%20the%20alternative%20material%20design%20or%20method%20of%20construction%20is%20not%20approved%20the%20building%20official%20shall%20respond%20in%20writing%20stating%20the%20reasons%20why%20the%20alternative%20was%20not%20approved AND <https://up.codes/viewer/colorado/ibc-2021/chapter/1/scope-and-administration#105.3.1>:-:text=If%20the%20application%20or%20the%20construction%20documents%20do%20not%20conform%20to%20the%20requirements%20of%20pertinent%20laws%20the%20building%20official%20shall%20reject%20such%20application%20in%20writing%20stating%20the%20reasons%20therefore
- 16 <https://up.codes/viewer/colorado/ibc-2021/chapter/17/special-inspections-and-tests#1707.1>:-:text=the%20building%20official%20shall%20accept%20duly%20authenticated%20reports%20from%20approved%20agencies%20in%20respect%20to%20the%20quality%20and%20manner%20of%20use%20of%20new%20materials%20or%20assemblies%20as%20provided%20for%20in%20Section%20104.11
- 17 <https://iaf.nu/en/about-iaf-mia/#>:-:text=it%20is%20required%20to%20recognize%20certificates%20and%20validation%20and%20verification%20statements%20issued%20by%20conformity%20assessment%20bodies%20accredited%20by%20all%20other%20signatories%20of%20the%20IAF%20MLA%20with%20the%20appropriate%20scope
- 18 True for all ANAB accredited product evaluation agencies and all International Trade Agreements.
- 19 <https://www.justice.gov/crt/deprivation-rights-under-color-law> AND <https://www.justice.gov/atr/mission>
- 20 Unless otherwise noted, all references in this Listing are from the 2021 version of the codes and the standards referenced therein. This material, product, design, service and/or method of construction also complies with the 2000-2021 versions of the referenced codes and the standards referenced therein.
- 21 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#p-3280.2>(Listed%20or%20certified); <https://up.codes/viewer/colorado/ibc-2021/chapter/2/definitions#listed> AND <https://up.codes/viewer/colorado/ibc-2021/chapter/2/definitions#labeled>
- 22 <https://up.codes/viewer/colorado/ibc-2021/chapter/17/special-inspections-and-tests#1703.4>
- 23 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#>:-:text=All%20construction%20methods%20shall%20be%20in%20conformance%20with%20accepted%20engineering%20practices%20to%20insure%20durable%20livable%20and%20safe%20housing%20and%20shall%20demonstrate%20acceptable%20workmanship%20reflecting%20journeyman%20quality%20of%20work%20of%20the%20various%20trades
- 24 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280#>:-:text=The%20strength%20and%20rigidity%20of%20the%20component%20parts%20and/or%20the%20integrated%20structure%20shall%20be%20determined%20by%20engineering%20analysis%20or%20by%20suitable%20load%20tests%20to%20simulate%20the%20actual%20loads%20and%20conditions%20of%20application%20that%20occur
- 25 Qualification is performed by a legislatively defined Accreditation Body. ANSI National Accreditation Board (ANAB) is the largest independent accreditation body in North America and provides services in more than 75 countries. DrJ is an ANAB accredited [product certification body](#).
- 26 See Code of Federal Regulations (CFR) Title 24 Subtitle B Chapter XX Part 3280 for definition.
- 27 [2018 IFC Section 104.9](#)
- 28 Approved is an adjective that modifies the noun after it. For example, Approved Agency means that the Agency is accepted officially as being suitable in a particular situation. This example conforms to IBC/IRC/IFC Section 201.4 where the building code authorizes sentences to have an ordinarily accepted meaning such as the context implies.
- 29 <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1707.1>



30 Multilateral approval is true for all ANAB accredited product evaluation agencies and all International Trade Agreements.  
 31 <http://www.drjengineering.org/AppendixC> AND <https://www.drjcertification.org/comell-2016-protection-trade-secrets>  
 32 <https://www.law.cornell.edu/uscode/text/18/1832#:~:text=imprisoned%20not%20more%20than%2010%20years>  
 33 <https://www.law.cornell.edu/uscode/text/18/1832#:~:text=Any%20organization%20that,has%20thereby%20avoided>  
 34 <https://up.codes/viewer/wyoming/ibc-2021/chapter/17/special-inspections-and-tests#1706.2>  
 35 IBC 2021, Section 1706.1 Conformance to Standards  
 36 IBC 2021, Section 1707 Alternative Test Procedure, 1707.1 General  
 37 See Section 11 for the distilled building code definition of **Approved**  
 38 Los Angeles Municipal Code, SEC. 98.0503. TESTING AGENCIES  
 39 <https://up.codes/viewer/california/ca-building-code-2022/chapter/17/special-inspections-and-tests#1707.1>  
 40 New York City, The Rules of the City of New York, § 101-07 Approved Agencies  
 41 New York City, The Rules of the City of New York, § 101-07 Approved Agencies  
 42 <https://up.codes/viewer/new-jersey/ibc-2018/chapter/17/special-inspections-and-tests#1707.1>  
 43 <https://www.nj.gov/dca/divisions/codes/codreg/ucc.html>  
 44 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3282/subpart-A/section-3282.14>  
 45 <https://www.ecfr.gov/current/title-24/subtitle-B/chapter-XX/part-3280>  
 46 IBC 2021, Section 1706 Design Strengths of Materials, 1706.2 New Materials. Adopted law pursuant to IBC model code language 1706.2.  
 47 IBC 2021, Section 1707 Alternative Test Procedure, 1707.1 General. Adopted law pursuant to IBC model code language 1707.1.  
 48 <https://www.nspe.org/resources/issues-and-advocacy/professional-policies-and-position-statements/regulation-professional> AND <https://apassociation.org/list-of-engineering-boards-in-each-state-archive/>  
 49 IBC 2021, Section 1706 Design Strengths of Materials, Section 1706.1 Conformance to Standards Adopted law pursuant to IBC model code language 1706.1.  
 50 <https://iaf.nu/en/about-iaf-mla/#:~:text=it%20is%20required%20to%20recognise%20certificates%20and%20validation%20and%20verification%20statements%20issued%20by%20conformity%20assessment%20bodies%20accredited%20by%20all%20other%20signatories%20of%20the%20IAF%20MLA%2C%20with%20the%20appropriate%20scope>  
 51 True for all ANAB accredited product evaluation agencies and all International Trade Agreements.  
 52 <https://www.justice.gov/crt/deprivation-rights-under-color-law> AND <https://www.justice.gov/atr/mission>